



Art.-Nr: KXU021SC
Exit sign Self-contained
Universal, SelfControl (SC), 1 h, 30 m, IP40, Polycarbonate, White

Innovative plastic emergency exit sign luminaire for universal mounting, in a conically tapering housing producing an appealing look. Suited to inscription on one or two sides.



Automatic monitoring of safety luminaire with SelfControl. Planning certainty is provided by tool-free, variable use of the pictograms on site. A set of pictograms corresponding to DIN ISO 7010 (arrow to the right, left, up and down) is supplied as standard. Universal mounting includes fitting on the wall and ceiling as well as the option of fitting in the ceiling in conjunction with the mounting frame available.



More information
www.rp-group.com/en/item/KXU021SC



TECHNICAL DATA

Luminaire type	Exit sign
Mounting	Universal
Recognition distance	30 m
Pictograph	Set
Illuminant	LED
Housing material	Polycarbonate
Housing color	White
Protection type (IP)	IP40
Impact resistance (IK)	≥ 3
Certification	WEEE, CE
Insulation class	2
Supply	Self-contained
Monitoring	SelfControl (SC)
Bridging time	1 h
Battery	NIMH 4,8 V/2,0 Ah
Operating mode	Non-maintained / maintained



Input voltage AC	230 V
Input frequency	50 / 60 Hz
Power max.	6 W
Power maintained	4,5 W
Power non-maintained	0,35 W
Ambient temperature maintained mode	-5 °C to 35 °C
Ambient temperature non-maintained mode	-5 °C to 40 °C
Depth	48 mm
Width	332 mm
Height	242 mm
Weight	1
Weight incl. packaging	1.11
Connection cross-section	2.5 mm ²
Switching input	Yes
Emergency light blocking	Yes
Battery connection	Connector
Dimming function	Yes
Luminous flux mains	430 lm
Luminous flux emergency	520 lm
Customs tariff number	94056120
GTIN	4260682144157



TECHNICAL DRAWING



ACCESSORY LIST

- KXE-EB -
- AWX001 -
- DSA - Wire suspension
- 2PW-EB - Pendant
- 2DW-EB -
- KXBE -
- NIMHHT4820Q - Battery



RELATED PRODUCTS

Art.-No.	Image	Monitoring	Supply	Color	Investment	Automatic log	Maintenance level	Remote maintenance	max. luminaires	Single luminaire monitoring
KXU021		Without monitoring		RAL 9003						

As of: 05.09.2025 - Subject to technical changes and errors.