

Project

Luminaire

Date


Created by

Extended Distance Table

EEQF023

2017-09-05

Christian Starker



Luminaire distance table for even escape routes

= valid distances in [m]

Mounting Height [m]	1	2	3	4	5
2,00	 6,16	 15,89	 12,84	 4,92	 1,80
2,50	 6,19	 17,44	 13,32	 5,08	 1,75
3,00	 5,41	 18,17	 12,00	 5,13	 1,60
3,50	 4,48	 18,19	 10,53	 5,05	 1,34
4,00	 3,13	 16,74	 8,72	 4,82	 1,00
5,00		 12,36	 4,78	 3,90	
6,00		 5,55	 1,87	 1,98	
7,00					
8,00					

Above values are valid for the following parameters: Emergency lighting factor: 1, Maintenance factor: 0,8, E_min on the center line: 1lx, E_min on the half width: 0,5lx, Maximum uniformity: 40:1, Width of escape route: 2m