

Project

Luminaire

Date


Created by

Extended Distance Table

EERF023

2017-09-05

Christian Starker



Luminaire distance table for even escape routes

= valid distances in [m]

Mounting Height [m]	1	2	3	4	5
2,00	6,16	15,89	12,84	4,92	1,80
2,50	6,19	17,44	13,32	5,08	1,75
3,00	5,41	18,17	12,00	5,13	1,60
3,50	4,48	18,19	10,53	5,05	1,34
4,00	3,13	16,74	8,72	4,82	1,00
5,00		12,36	4,78	3,90	
6,00		5,55	1,87	1,98	
7,00					
8,00					

Above values are valid for the following parameters: Emergency lighting factor: 1, Maintenance factor: 0,8, E_{min} on the center line: 1lx, E_{min} on the half width: 0,5lx, Maximum uniformity: 40:1, Width of escape route: 2m