

Project

Luminaire

Date

Created by

RP-Technik GmbH


Extended Distance Table

ILDR029

2015-12-22

Manuel Fenchel

Herrmann-Staudinger-Str. 10-16, 63110 Rodgau



Luminaire distance table for even escape routes

 = valid distances in [m]

Mounting Height [m]	1	2	3	4	5
2,00	4,95	11,32	11,34	11,36	4,95
2,50	5,62	13,23	13,26	13,29	5,62
3,00	5,41	14,85	14,89	14,93	5,41
3,50	4,64	15,66	15,71	15,81	4,82
4,00	1,38	14,56	14,61	14,50	1,38
5,00		10,98	11,16	11,18	
6,00		2,10	2,16	2,24	
7,00					
7,50					
8,00					
9,00					
10,50					
12,00					

Above values are valid for the following parameters: Emergency lighting factor: 1, Maintenance factor: 0,8, E_min on the center line: 1lx, E_min on the half width: 0,5lx, Maximum uniformity: 40:1, Width of escape route: 2m

Specifications subject to change without notice.

RP DIALux Extrapolator Version 1.0