

Project

Luminaire

Date

Created by

RP-Technik GmbH



Extended Distance Table

KBU011_Folie

2015-12-22


Manuel Fenchel

Herrmann-Staudinger-Str. 10-16, 63110 Rodgau



Luminaire distance table for even escape routes

= valid distances in [m]



Mounting Height [m]

	2,00	3,20	7,83	7,90	7,96	3,20
	2,50	3,44	8,64	8,71	8,77	3,44
	3,00	3,70	9,33	9,38	9,42	3,70
	3,50	3,75	9,90	9,92	9,95	3,75
	4,00	3,86	10,35	10,36	10,36	3,86
	5,00	3,90	10,98	10,94	10,88	3,76
	6,00	3,60	11,26	11,16	11,04	3,46
	7,00	3,12	11,24	11,04	10,84	2,82
	7,50	2,58	11,10	10,86	10,62	2,43
	8,00	1,84	10,88	10,58	10,28	1,70
	9,00		10,08	9,69	9,33	
	10,50		6,24	5,79	5,82	
	12,00		0,66	0,78	0,87	

Above values are valid for the following parameters: Emergency lighting factor: 1, Maintenance factor: 0,8, E_{min} on the center line: 1lx, E_{min} on the half width: 0,5lx, Maximum uniformity: 40:1, Width of escape route: 2m

Specifications subject to change without notice.

RP DIALux Extrapolator Version 1.0