

## Project

Luminaire

Date

Created by

RP-Technik GmbH


## Extended Distance Table

KWW013\_opal\_flach\_Pikto

2016-02-01

Manuel Fenchel

Herrmann-Staudinger-Str. 10-16, 63110 Rodgau



Luminaire distance table for even escape routes

  = valid distances in [m]

Mounting Height [m]	1	2	3	4	5
2,00	1,25	4,17	3,84	3,51	1,02
2,50	0,58	3,92	3,59	3,28	0,40
3,00		2,83	2,38	2,38	
3,50		1,29	1,00	1,00	
4,00					
5,00					
6,00					
7,00					
7,50					
8,00					
9,00					
10,50					
12,00					

Above values are valid for the following parameters: Emergency lighting factor: 1, Maintenance factor: 0,8,  $E_{min}$  on the center line: 1lx,  $E_{min}$  on the half width: 0,5lx, Maximum uniformity: 40:1, Width of escape route: 2m

Specifications subject to change without notice.

RP DIALux Extrapolator Version 1.0