

Project

Luminaire

Date

Created by

RP-Technik GmbH


Extended Distance Table

KWW013_weiß_flach_Pikto

2016-02-01

Manuel Fenchel

Herrmann-Staudinger-Str. 10-16, 63110 Rodgau



Luminaire distance table for even escape routes

 = valid distances in [m]

Mounting Height [m]	1	2	3	4	5
2,00	1,51	4,66	4,26	3,89	1,25
2,50	1,17	4,54	4,16	3,79	0,96
3,00		4,17	3,79	3,43	
3,50		2,73	2,27	2,27	
4,00		1,10	0,91	0,91	
5,00					
6,00					
7,00					
7,50					
8,00					
9,00					
10,50					
12,00					

Above values are valid for the following parameters: Emergency lighting factor: 1, Maintenance factor: 0,8, E_{min} on the center line: 1lx, E_{min} on the half width: 0,5lx, Maximum uniformity: 40:1, Width of escape route: 2m